

Water Analysis Report

PROFESSIONAL LABORATORIES

1675 North Commerce Parkway

Weston, Florida 33326

Phone: (954)384-4446 Fax #: (954)384-4838



"The Professional's Choice
For Environmental Testing"

Report Date 2/20/2008	Contact Name LARRY GRIFFITH	Customer ID 1352
Report ID 11387	Sample ID 40177	Sample Location ENVOR BLUE WAT
Sample Date 2/14/2008		Sample Type NO INFO

Client:

GRIFFITH & ASSOCIATES HOME INSPECTION

PO BOX 693386

MIAMI, FL 33269

Test Location:

2 GROVE ISLES #PH7

COCONUT GROVE, FL 33133

Fax: 3059316047

E-mail: GRIFFITHASSOCIATE@BELLSOUTH.N

John D. Shane Ph.D., QA Manager

COMPLETE WATER ANALYSIS

	Test Results	EPA Standard
Bacteria (Total Coliform)	0 CFU	0 CFU
E. Coli	0 CFU	0 CFU
Turbidity	0.35 NTU	5 NTU
Nitrates (mg/l as Nitrogen)	BDL mg/L	10 mg/L
Nitrites	BDL mg/L	1 mg/L
pH	6.75	6.5 - 8.5
Iron	BDL mg/L	.3 mg/L
Lead	BDL ppb	15 ppb
Alkalinity	12 ppm	80 - 180 ppm
Chloride	2.298 mg/l	<250 mg/l
Color	10 (CU)	15 (CU)
Copper	0.02 mg/L	1.3 mg/L
Hardness	12 PPM	50 PPM

mg/L = milligrams per liter

ppb = parts per billion

NTU = nephelometric turbidity units

CFU = colony forming units

BDL= the level is below the detection limit of 1 ppb

Analyst: 17

Results: The above parameters meet all the EPA general maximum contaminant levels for potable water established by EPA regulatory requirements.